



621 S Texas Blvd Suite A Weslaco TX 78596
 P: 956-854-4319

Email: customerservice@smithsecuritygroupllc.com
 Lic B19831 FAL - 2394429

Passed

FIRE ALARM INSPECTION REPORT

CUSTOMER: Valley Grande Institute (Main) DATE: 2-2-24
 STREET: 345 South Texas Blvd TIME: _____
 CITY & STATE: Weslaco TX 78599 TEL #: _____
 TYPE OF SERVICE NEW INSTALL QUARTERLY SEMI-ANNUAL ANNUAL
 CONTROL PANEL MFG: Ademco MODEL: Vista 32FB ZONES: _____

MONITORING ENTITY

CONTACT: Smith Sec & Fire TEL #: 956 854 4319 ACT.# 12-05-5279
 TRANSMISSION TYPE: DIGITAL REVERSE POLARITY RF OTHER Cell Unit

	# OF DEVICES	# TESTED	RESULTS ✓ OKAY	COMMENTS
Control Panel	1	1	✓	
Annunciators	1	1	✓	
Audio/Visual Devices	6	6	✓	
Visual Devices	8	8	✓	
Audible Devices				
Manual Pull Stations	4	4	✓	
Photoelectric Smoke Detectors	19	19	✓	
Ionization Smoke Detectors				
Duct Smoke Detectors				
Heat Detectors	1	1	✓	
Smoke Dampers				
Magnetic Door Locks/holders				
A.H.U. Fan Shutdowns				
Sprinkler Supervisory Devices				
Sprinkler Water Flow Devices				
Automatic Extinguishing System				
Remote Monitoring	1	1	✓	Starlink
Charger				
Batteries	2	2	✓	No Date
Battery Voltage	26.7V			
Power Supplies				
Other				

Inspector's Signature: [Signature] License#: FAL2872983
 Inspector's Printed Name: Joe Gonzalez

Customer's Signature: [Signature]
 Customer's Printed Name: _____